



Certificate of Compliance

Certificate: 80037768

Master Contract: 201383

Project: 80101820

Date Issued: 2021-11-03

Issued To: A-T Controls, Inc.
9955 International Blvd
Cincinnati, Ohio, 45246
United States

Attention: Pete Vezey

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Vajira Sarathchandra*
Vajira Sarathchandra

PRODUCTS

CLASS 3371 10 - VALVES (GAS) Lever Operated Non-Lubricated Shutoff

Manually Operated Ball Valves for gas applications

Tradename: ATControls

<i>Model</i>	<i>Diameter</i>
F88 Series 3 Piece Ball Valve	1/4", 3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3"
F90 Series Split Body Flanged Ball Valve	1/2", 3/4", 1", 1-1/2", 2", 2-1/2", 3", 4"
93 Series Split Body Flanged Ball Valve	6"
P1S-(L1,W1) Series Butterfly Valve	2", 3", 4", 6", 8"

Maximum Operating Pressure: 125 PSI
Temperature Range: -30°C to 65°C (-22°F to 149°F)

APPLICABLE REQUIREMENTS

CSA 3.16:21 Lever Operated Non-Lubricated Plug Type Gas Shut-Off Valves (*Fourth Edition*)



Supplement to Certificate of Compliance

Certificate: 80037768

Master Contract: 201383

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80101820	2021-11-03	Update to CSA 3.16:21 as per CSA Gas Inform No. 482
80065162	2021-02-10	Original Certification of Manual Butterfly Valves, P1S-(L1,W1) Series HPBV sizes 2", 3", 4", 6" and 8"; approved for CF8M Lug fitments or Wafer Fitment
80037768	2020-10-08	Original Certification of Manual Valves, 93 Series Flanged Ball Valve sizes 6"; F88 Series Threaded Valves sizes 1/4", 3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3"; F90 Series Threaded Valves sizes 1/2", 3/4", 1", 1-1/2", 2", 2-1/2", 3", 4" - Variants in SST and WCB.